



कार्यालय नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर।

पत्रांक:- 682/D/80A/NSA

दिनांक:- 24/8/2020

प्रमाण पत्र

प्रमाणित किया जाता है की सफाई एवं खाद्य निरीक्षक/केमिस्ट स्वास्थ्य विभाग द्वारा दिनांक 20.08.2020 को दून इन्टरनेशनल स्कूल, 392 रतन लाल नगर, कानपुर नगर का निरीक्षण किया गया तथा पानी का सैम्पल लिया गया जिसमें पेयजल की गुणवत्ता पेययोग्य एवं विद्यालय में सेनेटरी एवं हाइजेनिक स्थितियां हैल्थ मैनुअल के अनुरूप सही पायी गयी है।


नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the MLD DOON INTERNATIONAL SCHOOL
Sample taken from — — — Tubewell — 392, Ratan Lal Nagar Kanpur
Date of sample Drawn — — — 20/08/2020 — — —
Date of analysis — — — 20/08/2020 — — —
Physical Character — — — Transparent — — —
P. H. Value — — — 8.4 — — —
Free Ammonia Parts per 1000000 — — — NIL — — —
Albuminoid Ammonia Part per 1000000 — — — NIL — — —
Oxygen absorbed from pot. Permanganate
in three hours at 37° C — — — 0.6 — — —
Chloride Part per 1000000 — — — 9.0 — — —
Nitrites Parts per 1000000 — — — NIL — — —
Nitrates Parts per 1000000 — — — NIL — — —
Total solid part per 100000 — — — 520.0 — — —
Fixed solid Parts per 1000000 — — — 460.0 — — —
Volatils solid Parts per 100000 — — — 60.0 — — —
Appearance on ignition — — — No Charring — — —
Total hardness Parts per 1000000 — — — 98.0 — — —
Permanent hardness Parts per 1000000 — — — 76.0 — — —
Temporary hardness Parts per 1000000 — — — 22.0 — — —

Remarks :

'Potable'

No. 149/30A dated 24/08/2020
Copy forwarded for favour or information to

- 1) MLD Doon International School
392 Ratan Lal Nagar Kanpur
- 2) N.S.A. Abegor Nigam Kanpur

Nagar Swasthya Adhikari
Nagar Nigam Kanpur

Atkasingh